

ORDINANCE NO. 610.1-E-7-2008

CITY OF FRANKLIN, KENTUCKY

**AMENDMENT TO SEWER USE ORDINANCE
AND
USER CHARGE SYSTEM**

An ordinance of the City of Franklin, Kentucky, amending a previous ordinance relating to the use of the municipally-owned sewer system of said City, deleting certain provisions and adding certain new provisions which comply with state and federal regulations.

WHEREAS, it has become necessary to amend the existing Sewer Use Ordinance to provide further limitations on the discharge of pollutants into the sewer system.

NOW, THEREFORE, BE IT ORDAINED BY THE CITY OF FRANKLIN, KENTUCKY, ACTING BY AND THROUGH ITS COMMISSION, AS FOLLOWS:

Section V. (2) is hereby amended to read as follows:

In order to insure optimum and efficient operation of the Franklin wastewater treatment facilities, "Protection Criteria Parameters" as given in Table 1 have been developed. These parameters are goals to protect the treatment system and are for the influent to the treatment facilities. A table of "Local Effluent Limits for Industrial Users" is included as Table 2. This table establishes maximum effluent limits for individual discharges.

TABLE 1
PROTECTION CRITERIA PARAMETERS

<u>Constituent</u>	<u>Daily Maximum Concentration (mg/L)</u>
<u>Compatible Pollutants</u>	
<u>Biochemical Oxygen Demand</u>	<u>300</u>
<u>Chemical Oxygen Demand</u>	<u>600</u>
<u>Total Suspended Solids</u>	<u>300</u>
<u>Nitrogen (Total Kjeldahl)</u>	<u>60</u>
<u>Nitrogen (Ammonia)</u>	<u>20</u>
<u>Fats, Oil and Grease</u>	<u>100</u>
<u>PH</u>	<u>6-9</u>

Daily Maximum
Concentration (mg/L)

Constituent

Incompatible Pollutants:

Antimony	5.0
Arsenic	<u>0.6</u>
Boron	1.0
Cadmium	<u>0.36</u>
Chromium (Total)	<u>3.0</u>
Copper	<u>0.53</u>
Cyanide, <u>Amenable</u>	1.0
Lead	<u>0.2</u>
Mercury	<u>0.0005</u>
Nickel	<u>2.7</u>
Pesticides	0.001
Phosphorus	REPORT
Selenium	<u>0.045</u>
Silver	<u>0.26</u>
TPH	<u>Report</u>
TTO	2.13
Zinc	<u>2.46</u>

TABLE 2
LOCAL EFFLUENT LIMITS FOR INDUSTRIAL USERS

Constituent

Daily Maximum
Concentration (mg/L)

Compatible Pollutants

Biochemical Oxygen Demand	<u>300</u>
Chemical Oxygen Demand	<u>600</u>
Total Suspended Solids	<u>300</u>
Nitrogen (Total Kjeldahl)	<u>60</u>
Nitrogen (Ammonia)	<u>20</u>
Fats, Oil and Grease	<u>100</u>
PH	<u>6-9</u>

Constituents

Daily Maximum
Concentration (mg/L)

Incompatible Pollutants:

Antimony	5.0
Arsenic	0.6
Boron	1.0
Cadmium	<u>0.36</u>

- Scott Crabtree 7/7/08 4:23 PM
Deleted: 1.0
- Scott Crabtree 7/7/08 4:25 PM
Deleted: 0.02
- Scott Crabtree 7/7/08 4:25 PM
Deleted: Chromium (hexavalent)
- Scott Crabtree 7/7/08 4:25 PM
Deleted: 0.5
- Scott Crabtree 7/7/08 4:25 PM
Deleted: 2.0
- Scott Crabtree 7/7/08 4:26 PM
Deleted: 1.0
- Scott Crabtree 7/7/08 4:26 PM
Deleted: 0.1
- Scott Crabtree 7/7/08 4:27 PM
Deleted: 0.05
- Scott Crabtree 7/7/08 4:27 PM
Deleted: 3.0
- Scott Crabtree 7/7/08 4:28 PM
Formatted: Font:Verdana, 11 pt, No
- Scott Crabtree 7/7/08 4:28 PM
Deleted: (Total)
- Scott Crabtree 7/7/08 4:27 PM
Deleted: 0.1
- Scott Crabtree 7/7/08 4:29 PM
Deleted: 1.0
- Scott Crabtree 7/8/08 10:06 AM
Deleted: Total Toxic Organics (
- Scott Crabtree 7/8/08 10:06 AM
Deleted:)
- Scott Crabtree 7/7/08 4:29 PM
Deleted: 3.4

Chromium (Total)	3.0
Copper	<u>0.53</u>
Cyanide, <u>Amenable</u>	1.0
Lead	0.2
Mercury	<u>0.0005</u>
Nickel	2.7
Pesticides	0.001
Phosphorus	REPORT
Silver	0.26
<u>TPH</u>	<u>Report</u>
<u>TTO</u>	2.13
Zinc	<u>2.46</u>
Selenium	<u>0.045</u>

- Scott Crabtree 7/8/08 10:11 AM
Deleted: 1.69
- Scott Crabtree 7/8/08 10:12 AM
Deleted: 0.001
- Scott Crabtree 7/8/08 10:13 AM
Deleted: (Total)
- Scott Crabtree 7/8/08 10:13 AM
Deleted: -
- Scott Crabtree 7/8/08 10:15 AM
Deleted: 0.1
- Scott Crabtree 7/8/08 10:13 AM
Formatted: Font:Verdana, 11 pt, No
- Scott Crabtree 7/8/08 10:14 AM
Deleted: Total Toxic Organics (
- Scott Crabtree 7/8/08 10:14 AM
Deleted:)
- Scott Crabtree 7/8/08 10:15 AM
Deleted: 3.40

If any section, subsection, sentence, clause, phrase, or portion of this ordinance is for any reason held invalid or unconstitutional by any Court of competent jurisdiction, such portion shall be deemed a separate, distinct, and independent provision, and such holdings shall not affect the validity of the remaining portions of Ordinance.

All ordinances or parts of ordinances in conflict herewith, are, to the extent of such conflict, hereby repealed.

FIRST READING July 14, 2008 SECOND READING July 28, 2008

At a meeting of the City Commission of the City of Franklin, Kentucky, held on July 28, 2008, on motion made by Commissioner Henry Stone and seconded by Commissioner Herbert Williams, the foregoing ordinance was adopted, after full discussion, by the following vote:

<u>YES</u> HERBERT WILLIAMS	<u>YES</u> BILL AUSTIN
<u>YES</u> WENDELL STEWART	<u>YES</u> HENRY STONE
<u>YES</u> JIM BROWN, MAYOR	

APPROVED BY:

JIM BROWN, MAYOR

ATTEST:

KATHY STRADTNER, CITY CLERK
CITY OF FRANKLIN, KENTUCKY