

The Water Plant News

September 2011

LAB SAMPLES FOR JULY

- 10 Bac-T samples
- 2 Fluoride samples
- 1 TOC sample
- TSS sample

August safety meeting: Control Panel Safety.

August M.O.R. mailed on September 1.



The mag meter is installed and is now connected to the totalizer (at left). We can now record the data from the new meter. The new meter should be much more accurate than the 25 year old meter it replaced. The new meter uses a magnetic field to determine the flow and has no moving parts.

The Water Plant News

September 2011



Above is some of the lab equipment (turbidimeter and pH meter/probe) that received annual calibration in August. This is required so that the state knows the numbers we record are as accurate as possible.